***READ & SAVE THESE INSTRUCTIONS *** MODEL 63013, 63014, 63015, ACCESS LIGHTING INSTALLATION & OPERATION INSTRUCTIONS

1) TOOLS AND MATERIALS REQUIRED

- Flat Head Screw Driver
- Star Screw Driver
- Wire Cutters
- Supplies as required by Electrical Code

Attention:

Before assembling your lighting fixture, please read the following instructions.

(2) GENERAL

- To ensure the success of the installation, be sure to read these instructions thoroughly before beginning.
- All electrical connections must be in accordance with local codes, ordinances, or the National Electrical Code. If you are unfamiliar with methods of installing electrical wiring, secure the services of a qualified licensed electrician.
- These fixtures are intended for mounting to a standard 4" x 2 ¼" deep metal octagon outlet box. The box must be directly supported by the building structure and U.L. Recognized.
- Before commencing with the installation, disconnect the power by turning off the circuit breaker or by removing the fuse at the fuse box. Turning the power off using the light switch is not sufficient to prevent electrical shock.

NOTE:

The important safeguards and instructions appearing in this manual are not meant to cover all possible conditions and situations that may occur. It must be understood that common sense, caution and care, are factors that cannot be built into any product. The person(s) caring for and operating the fixture must supply these factors.

(3) UNPACKING THE FIXTURE

On checking the contents of the box you will find;

- 1. Fixture assembly
- 2. 1 x Cross Bar/Screws and Wire nuts
- 3. Metal Rings
- 4. Springs
- 5. 3 x MR16/50W or 5 x MR16/35W

CAUTION:

- Ensure that the Fitting is Cool and Switched off, Before Changing the Halogen Bulb.
- Do Not use Bulbs Exceeding Maximum Wattage, As Per Caution Label.
- Do Not use uncovered MR16 Bulbs.
- Do Not Touch the Halogen Bulb or Protective Glass while fixture is in operation.

Do not install this fixture assembly closer than 6 inches from any curtain or similar combustible material.

Warning-Risk of fire and electric shock. Important safety instructions. Do not install this fixture in hazardous locations.

(4) PREPARE THE FIXTURE

Refer to figure I for illustration of fixture parts and assembly.

- 1. Carefully lay the fixture on a soft flat surface.
- 2. Loosen thumb screw on canopy and remove canopy.
- Remove the two lock nuts securing the transformer to the mounting plate and heat sync plates. Remove the nipple.
- 4. Identify the thin black and white wires protruding from transformer (120V wires.) These wires can also be identified by "Main Supply" label. Identify the thick blue wires protruding from the transformer at one end and inserted into the terminal block at the other end-these are the 12V wires. Remove these wires from the terminal block by unscrewing the two screws.
- 5. Mount the **crossbar** to the **J-box**, using the screws supplied.
- 6. MAKE SURE ELECTRICITY IS OFF. Screw the nipple into the crossbar allowing +/- 1/8" extension above the top of the crossbar. Secure the nipple to the crossbar with one of the lock nuts (place this lock nut below the crossbar, not above). The ground wire from your power supply must be connected to the green screw attached to the crossbar. Make sure that all wire connections are very secure. Secure the connection with U.L listed Electrical Tape.
- 7. Feed the two **supply wires** through the large hole in the **back plate**. Hold the **back plate** up to the ceiling; fit the **nipple** through the center of the **back plate**, first **heat sync plate**, **transformer** and finally the second **heat sync plate**. Secure with the remaining **lock nut**.
- 8. MAKE SURE ELECTRICITY IS OFF. Using the wire nuts supplied, make connection between the line voltage wires from transformer (120V) and your supply wires. The black supply wire gets connected to the black transformer wire and the white supply wire gets connected to the white transformer wire. Make sure that all wire connections are very secure. Secure the connection with U.L listed Electrical Tape.
- Re-attach the thick blue (12V) wires from the transformer to the terminal block. Ensure that all connections are very tight to prevent arcing.
- 10. Hold the fixture canopy up to the transformer, fit the nipple through the center of the canopy and secure with the supplied thumb nut.
- 11. Screw the supplied **rods** into the body of the fixture.
- Screw top portion of rod into the Hang-Straight Nipple attached to the canopy.
- 13. Insert the MR16 bulbs into the socket. Make sure that the pins of the bulb are aligned with the socket holes. When replacing bulbs-DO NOT EXCEED WATTAGE AS INDICATED BY WARNING LABEL.
- Insert one side of spring into the hole located on the outside of the socket. Repeat procedure with a second spring into the remaining hole around the socket. (Each socket requires two springs).
- Place spring attached to outside of socket into hole on outside of ring. Repeat procedure with remaining spring.
- Restore Electricity and check the operation of your new lighting fixture.