





80 CFM/<0.3 Sones @ 0.10" SP.

Boost Speed: 110 CFM/0.6 Sones @ 0.10" SP., 87 CFM @ 0.25" SP.

Grill

White, polymeric grill secured in place with torsion springs; easily removed if necessary, dimensions - 17" x 15^7 /s".

Blower Wheel

Balanced polymeric dual inlet blower wheel secured in place using a hex nut.

Motor

Enclosed 4 pole high efficiency, permanently split capacitor motor (PSC); life time lubrication, suitable for continuous operation. Rated 115/120 volts, 60 Hz.

Fan Housing

23 gauge galvanized steel housing. Fan housing dimensions: $12^{7/8}$ "x $12^{3/4}$ "x $9^{7/8}$ ".

Humidity Sensor

Integrated humidity sensor automatically turns fan on until the desired humidity level is reached.

Duct Collar


6" round, zinc plated metal collar adapter. 6" spring loaded and gasketed aluminum backdraft damper.

Electrical Connections

0.5" electrical knockouts provided. Easy wiring access via either internal or external wiring compartment cover.

I iahtina

Dimmable LED Lamp rated 8.5 Watts 800 Lumens 94 Lumens/Watt, 3000K. California Title 24 and JA8 compliant.



Acceptable for use over tub or shower when installed in a GFCI protected branch circuit.

COMPLES WITH ASHRAE 62.2

Unit Mounting

The housing will mount through drywall thickness up to 3/4", with a rough-in opening of 131/8" x 13". The housing will mount either between 16" or 24" on center joists, using the 2 supplied housing mounting brackets. The housing mounting brackets can be adapted for overhead mounting (hardware not provided). The unit is provided with an optionally installed ceiling flange to ensure proper building infiltration rates are maintained and that no air leaks occur between the fan housing and ceiling cutout.

	Static Pressure (inches of w.g.)							Sones @ .1 SP	Fan Speed RPM	Maximum Fan Watts	Full Load Amps
	0	0.05	0.1	0.15	0.20	0.25*	0.375				
Air Flow - CFM	101	90	80	70	59	49/87	5	< 0.3	843	37.0	0.7

* Boost speed provides 87 CFM @ .25 Static Pressure, 0.6 sones

PROJECT							ARCHITECT			
LOCATION							ENGINEER			
CONTRACTOR							SUBMITTI	ED BY	DATE	
FAN Number	MODEL NUMBER	CFM	IN W.G.	RPM	WATTS	AMPS	SONES	QTY	OPTIONAL EQUIPMENT & REMARKS	







U.S.: 820 Lincoln Avenue West Chester, Pennsylvania 19380-4466 Tel: (610) 692-7400 ● 877-304-3785 Fax: (610) 696-8048 Canada: Brampton, Ontario Tel: 905-456-2033 Fax: (905) 456-1015

Specifications subject to change without notice. Updated 7-21