

- Complies with American National Standard Z358.1
- Galvanized Steel Pipe and Waste Tee with Floor Flange Protected with BradTect<sup>®</sup> Safety Yellow Coating
- · Universal Identification Sign and Inspection Tag Included
- Full, One-Year Warranty
- · Classified by Underwriters Laboratory Inc. to ANSI Z358.1

## **Specifications**

Unit design saves space and fits easily into any work environment. Eyewash operates quickly by a large, highly visible push handle. Safe, steady water flow under varying water supply conditions from 30-90 PSI is assured by integral flow control in the sprayhead assembly. NOTE: The ANSI Z358.1 standard requires an uninterruptible supply of flushing fluid at a minimum 30 PSI flowing pressure.



This plumbing fixture is not intended to dispense water for human consumption through drinking or for preparation of food or beverages.

# Standard Equipment

## **Eyewash Bowl**

10" (254mm) diameter yellow impact resistant plastic.

## Standard Sprayhead Assembly

Chrome-plated brass sprayhead assembly with twin soft-flow eyewash heads and protective sprayhead covers. Safe, steady water flow under varying water supply conditions from 30-90 PSI is assured by integral flow control in the sprayhead assembly.

#### Valve

Chrome-plated brass  $\frac{1}{2}$ " NPT stay-open ball valve. Hand-operated by a large, highly visible push handle.

### **Pipe and Fittings**

Galvanized steel and waste tee with floor flange protected with BradTect® safety yellow coating.


### Waste

11/4" drain fitting furnished.

### **Water Supply**

1/2" NPT.






Model Number		Description
	S19-210	Pedestal-Mounted Eyewash Unit with Plastic Bowl
	S19-2000	Navigator EFX8 – Emergency Thermostatic Mixing Valve







NOTE: All dimensions assume standard thread engagement. Variations in manufacturing allow for +/- 1/8" (3mm) per threaded joint. To find the tolerance of a dimension, add the number of thread joints in between a dimension and multiply it by 1/8" (3mm).

bradleycorp.com