

SPECIFICATION SUBMITTAL SHEET


J O N E S S T E P H E N S C O R P O R A T I O N

INLINE PVC CHECK VALVE

specification submittal sheet

PART NO. C31-050

- Stainless steel spring
- EPDM seats
- Maintenance-free operation
- .5 psi required to open unit
- 200 psi static pressure rating at 77° F
- Use anywhere to stop backflow and siphoning
 - Swimming Pools
 - Hot Tubs
 - Spas
 - Solar Installations



PART NO.	DESCRIPTION	A	B	C	D
□ C31-050	1/2" IPS Check Valve	2"	1-1/4"	1-3/4"	4"

from **Jones Stephens Corp.**
PlumBest

updated 07/14/03

Quality Products for the Plumbing Professional

3249 Moody Parkway • Moody, Alabama • 205•640•7200 • Toll Free 1•800•35•JONES
Fax (205) 640-7070 • Toll Free Fax 1•800•462•6991
www.plumbest.com