

Anglesey™

Top spud antimicrobial flushometer bowl with bedpan lugs

K-4386-SS

Features

- Elongated bowl offers added room and comfort
- Angle back and wall outlet
- 1-1/2" (38 mm) top spud
- 2-3/8" (60 mm) passageway
- 11" (279 mm) x 9-1/2" (241 mm) water area
- 4-1/2" (114 mm) rough-in
- 1.6 gpf (6.0 lpf)
- Antimicrobial finish inhibits the growth of mold-, mildew-, stain-, and odor-causing bacteria on the fixture surface. This product does not protect users against bacteria, viruses, or other disease organisms. Always clean and wash this product thoroughly before and after each use



Codes/Standards

ASME A112.19.2/CSA B45.1 DOE - Energy Policy Act 1992

KOHLER® One-Year Limited Warranty

See website for detailed warranty information.

Available Colors/Finishes

Color tiles intended for reference only.

Color Code Description

0 White

Material

Vitreous china






Anglesey™

Top spud antimicrobial flushometer bowl with bedpan lugs

K-4386-SS



Technical Information

All product dimensions are nominal.

Toilet type: Floor-mount

Waste Outlet: Wall Bowl shape: Elon

Bowl shape: Elongated
Spud size: 1-1/2"", Inlet, Top
Trap passageway: 2-1/2" (63 mm)

Water surface size: 11" x 9-1/2" (279 mm x 241 mm)

Rim to water 5-1/4" (133 mm)

surface:

Rough-in: 4-1/2" (114 mm) Seat-mounting 5-1/2" (140 mm)

holes:

Fixture Supply Requirements

Min static pressure: 35 psi (241.3 kPa)
Max static pressure: 80 psi (551.6 kPa)
Min flowing 25 psi (172.4 kPa)

pressure:

Min flow rate: 25 gpm (94.6 lpm)


Notes

Install this product according to the installation instructions.

Refer to manufacturer's instructions and local codes for flushometer requirements.

For back-to-back toilet installations: Use only a 45° double wye fitting.

Product dimensions are nominal and may vary per ASME A112.19.2 tolerances.



Kohler Co. reserves the right to make revisions without notice to product specifications. For the most current Specification Sheet, go to www.kohler.com USA or www.kohler.ca Canada 10-31-2025 23:01 - US

