# **NuTone**

## **DESCRIPTION**

- · UL Listed for use in commercial applications
- · Watertight electrical terminal box
- · Totally enclosed motor
- · High-efficiency motorized impeller
- Automatic reset thermal overload protection

# **DESIGN FEATURES**

Air delivery: 140 CFM at 0.2" S.P.

Sound Level: N/A - unit is remotely mounted


**Amps: 0.7** 

**Housing:** UV-resistant, durable polycarbonate plastic **Motor:** External rotor, ball bearing, 115 volts AC, 60 Hz

**Blower Wheel:** Backward inclined centrifugal **Duct Size:** 4" (102 mm) or 5" (127 mm) diameter


#### INSTALLATION

- · Not for use in cooking areas
- Approved for mounting in wet locations (outdoors)
- Suitable for use over a tub or shower when connected to a GFCI-protected branch circuit
- · Suitable for use with solid-state speed controls




# **In-Line Radon Fan**

# **MODEL ILRF**



### TYPICAL SPECIFICATIONS

- · Unit shall be NuTone model ILRF
- Housing shall be constructed from UV resistant durable plastic
- Unit shall include a watertight electrical terminal box and factory sealing to prevent water damage to interior
- Unit shall be approved for use in wet locations
- Unit shal include a motorized impeller for high efficiency performance, with automatic reset thermal overload protection
- Air delivery shall no be less than 140 CFM (66 L/s). Air rating shall be conducted at an HVI recognized testing facility. Unit shall be cULus Listed.





HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.2 in. static pressure, based on tests conducted in a state-of-the-art test laboratory.

Broan-NuTone LLC Hartford, Wisconsin www.nutone.com 1-888-336-3948 Broan-NuTone Canada Inc. Mississauga, Ontario www.nutone.ca 1-877-896-1119

REFERENCE	QTY.	REMARKS	Project	
			Location	
			Architect	
			Engineer	
			Contractor	
			Submitted by	Date