




TempGuard™ COLD
Temperature sensor for disabling
fresh air damper in extreme cold.

Specifications:

Off temp: 35°F +/- 5°
On temp: 4° F higher

2A @ 24VAC

Wiring Diagram



Installation:

Drill a 1/2" hole in duct on
the cold air side of damper.

Fasten sensor with 2 self
tapping screws provided.

Wire according to diagram.

TempGuard™ COLD
Temperature Sensor

ITEM NO. ACTG-H01



8 5770200111 4



AirCycler
www.AirCycler.com