Tes

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

B-0407-03

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

		This Space for Architect/Enginee	r Approval		
995		Job Name	Date		
		Model Specified	Quantity		
	Ø1 11/16"	Customer/Wholesaler			
	[43mm]	Contractor			
		Architect/Engineer			
	∕─3/8" NPT Atmospheric Vacuum Breaker Not For	0.040			
	Continuous Pressure	8 9/16" [218mm]			
	071X 9" Nozzle w/ Stream Regulator Outlet 4 13/16" [122mm]				
	Standard T&S Swivel Outlet				

Product Specifications:

Vacuum Breaker Swing Nozzle w/ Stream Regulator Outlet and 8 5/8" Spread

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ASSE 1001 (VB)

Drawn: KJG Checked: JRM Approved: JHB Date: 09/17/18 Scale: 1:3 Sheet: 1 of 1



T&S BRASS AND BRONZE WORKS, INC. 2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690


Model No.

B-0407-03

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

ITEM NO.	SALES NO.	DESCRIPTION			
1	B-0968	3/8" NPT Vacuum Breaker			
2	001043-45	Washer			
3	B-LT	Stream Regulator Outlet O-Ring			
4	001074-45				
5	009538-45	Swivel Washer			
6	071X	9" Nozzle			



Product Specifications:

Vacuum Breaker Swing Nozzle w/ Stream Regulator Outlet and 8 5/8" Spread

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ASSE 1001 (VB)

Drawn:	KJG	Checked:	JRM	Approved:	JHB	Date:	09/17/18	Scale:	NTS	Sheet: 2 of 2